

Compliance Summary Report

Compliance Summary Report of **J & J HOME #2 31Mar2013** on **J & J Residential Services, Inc.**

Reviewer: **Rob Auer**

Provider: **J & J Residential Services, Inc.**

County Name: **Jefferson County**

Total Cites: **1**

Total POCs: **1**

CITE #1

Question	Explanation	
Are the interior, exterior and grounds of the building maintained in good repair and in a clean and sanitary manner?	The fire escape railing is wobbly, and the middle stairwat vertical support was free floating, and the bottom step needs supported.	
POC	Status	Comments
The Fire escape will be fixed by April 30th 2013. The railing will be replaced by a 2 by 4. The middle vertical support will be replaced by a 4by4. The bottom step will be replaced by a cement base.	Approved	